CIRCLE K SOUTHWEST PROTOTYPE 4480 - 08/13/2013

## GENERAL NOTES

A. PROVIDE ALL HEATING, VENTILATING AND AIR CONDITIONING ITEMS INDICATED ON THE DRAWINGS, DESCRIBED IN THIS SPECIFICATION, OR REQUIRED FOR A COMPLETE AND PROPER INSTALLATION. HVAC WORK INCLUDES THE FOLLOWING:

1. HVAC UNITS AND ACCESSORIES;
2. EXHAUST FANS;
3. DUCTS, FILTERS, DAMPERS, GRILLES, REGISTERS, DIFFUSERS;
4. CONTROLS, INCLUDING 24 VOLT CONTROL WIRING AND 120/24 VOLT TRANSFORMERS;
5. CONDUIT FOR LOW VOLTAGE WIRING;
6. INSULATION FOR DUCTS AS REQUIRED IN THIS SECTION;
7. CONDENSATE PIPING AND APPURTENANCES;
8. FLASHING FOR HVAC SYSTEMS THAT PENETRATE WALLS AND ROOFS;

B. FURNISH, WITHOUT EXTRA CHARGE, ANY ADDITIONAL MATERIAL AND LABOR REQUIRED TO COMPLY WITH THE ABOVE CODES AND STANDARDS, EVEN THOUGH THE WORK MAY NOT BE DESCRIBED IN THE CONTRACT DOCUMENTS. WHERE THE REQUIREMENTS OF THE CONTRACT DOCUMENTS EXCEED THE REQUIREMENTS OF THE ABOVE CODES AND STANDARDS, THE CONTRACT DOCUMENTS SHALL TAKE PRECEDENCE.

C. AFTER AWARD OF CONTRACT AND BEFORE COMMENCING WORK, IF REQUESTED BY CIRCLE K PROJECT ENGINEER, SUBMIT SIX COPIES OF THE FOLLOWING TO THE ARCHITECT FOR APPROVAL. SUBMITTALS SHALL BE IN BROCHURE FORM WITH INDEX AND SELECTED ITEMS CLEARLY DESIGNATED AND REFERENCED TO THE APPROPRIATE EQUIPMENT TAG NUMBER:

1. COMPLETE MATERIALS LIST OF ALL ITEMS PROPOSED TO BE FURNISHED AND INSTALLED UNDER THIS SECTION;
2. CATALOG CUTS AND OTHER DATA REQUIRED TO DEMONSTRATE COMPLIANCE WITH THE CONTRACT DOCUMENTS.

D. COOPERATE WITH OTHER TRADES IN ORDER THAT ALL SYSTEMS IN THE WORK MAY BE INSTALLED IN THE BEST ARRANGEMENT.

E. EXAMINE THE AREAS AND CONDITIONS UNDER WHICH WORK OF THIS SECTION WILL BE INSTALLED. CORRECT CONDITIONS DETRIMENTAL TO THE PROPER AND TIMELY COMPLETION OF THE WORK. NOTIFY ARCHITECT OF ANY DISCREPANCIES. DO NOT PROCEED UNTIL UNSATISFACTORY CONDITIONS HAVE BEEN CORRECTED.

F. AVOID INTERFERENCE WITH STRUCTURE, AND WITH WORK OF OTHER TRADES. INSTALL ALL EQUIPMENT PER MANUFACTURER'S INSTRUCTIONS. INSTALL ACCESSIBLE PARTS, INCLUDING EQUIPMENT, COILS, VALVES, DAMPERS, CONTROLS, AND FILTERS WITH ADEQUATE CLEARANCE FOR INSPECTION,ADJUSTMENTS, REPAIR, AND REPLACEMENT.

G. ALL OTHER MATERIALS, NOT SPECIFICALLY DESCRIBED BUT REQUIRED FOR A COMPLETE AND PROPER INSTALLATION, SHALL BE AS SELECTED BY THE CONTRACTOR SUBJECT TO ACCEPTANCE BY THE ENGINEER.

H. ALL PIPING AND DUCTS IN FINISHED ROOMS OR SPACES SHALL BE CONCEALED IN FURRED CHASES OR SUSPENDED CEILINGS, UNLESS OTHERWISE NOTED.

I. PROVIDE ACCESS PANELS OR DOORS IN UNACCESSIBLE CEILINGS AND/OR CHASES FOR ALL VALVES, TRAPS, DAMPERS, CLEANOUTS, COILS, FANS, CONTROLS, ETC. ACCESS DOOR RATING SHALL MATCH CLASSIFICATION OF WALL AND CEILING FIRE RATING.

J. COORDINATE THE LOCATION OF ALL DIFFUSERS, GRILLES, REGISTERS, ACCESS DOORS, ETC., WITH THE ARCHITECTURAL REFLECTED CEILING PLAN(S).

K. ALL ROUND RUNOUTS AND DROPS TO DIFFUSERS SHALL BE THE SAME NOMINAL SIZE AS THE SCHEDULED DIFFUSER NECK SIZE.

L. THE FIRST FIGURE OF DUCT SIZE INDICATES DIMENSION OF FACE SHOWN OR INDICATED. ALL DUCT SIZES SHOWN ON DRAWINGS ARE NET INSIDE DIMENSIONS.

M. PROVIDE TURNING VANES IN ALL SQUARE ELBOWS. EXCEPT TRANSFER AIR SOUND ELBOWS.

N. THE CFM OF EACH DIFFUSER, REGISTER, ETC., IS INDICATED IN THE SYMBOL DESIGNATION ON THE DRAWINGS.

O. DO NOT CUT INTO OR REDUCE THE SIZE OF ANY STRUCTURAL MEMBER WITHOUT THE PERMISSION OF THE ARCHITECT.

P. CONTRACTOR SHALL COORDINATE ALL DUCTWORK, PIPING, PLUMBING AND FIRE PROTECTION PIPING WITH STRUCTURAL AND ELECTRICAL SYSTEMS AND SHALL PROVIDE NECESSARY OFFSETS TO AVOID CONFLICTS AND TO MAINTAIN EQUIPMENT ACCESS AND SERVICEABILITY.

Q. CONTRACTOR SHALL FURNISH ALL NECESSARY STRUCTURES, INSERTS, SLEEVES, AND HANGING DEVICES FOR INSTALLATION OF MECHANICAL AND PLUMBING EQUIPMENT, DUCTWORK AND PIPING, ETC. CONTRACTOR SHALL COORDINATE WITH GENERAL CONTRACTOR AND ALL BUILDING TRADES TO AVOID CONFLICTS AND TO MAINTAIN EQUIPMENT ACCESS AND SERVICEABILITY.

R. CONTRACTOR SHALL BE RESPONSIBLE FOR PROVIDING ALL NECESSARY MISCELLANEOUS ANGLES, CHANNELS, UNISTRUT, ETC., AS MAY BE REQUIRED TO ADEQUATELY SUPPORT THE MECHANICAL PIPING, DUCTWORK, AND EQUIPMENT IN A MANNER APPROVED BY THE ARCHITECT WHICH WILL NOT OVERLOAD THE BUILDING STRUCTURAL SYSTEM.

S. CONTRACTOR SHALL PROVIDE RETURN AIR OR TRANSFER AIR OPENINGS IN FULL HEIGHT WALLS SIZED AT 500 FPM (UNLESS OTHERWISE SPECIFICALLY SHOWN ON THE DRAWINGS) TO CREATE AND/OR MAINTAIN A RETURN AIR PATH AS REQUIRED. FIRE DAMPERS AND/OR SMOKE DAMPERS SHALL BE PROVIDED IN SUCH OPENINGS WHERE REQUIRED BY NOTE "H".

T. SEAL ALL TRANSVERSE JOINTS, LONGITUDINAL SEAMS, DUCT WALL PENETRATIONS AND FITTING CONNECTIONS ON ALL DUCT SYSTEMS..

U. NOTIFY CIRCLE K PROJECT ENGINEER AT LEAST 24 HOURS PRIOR TO COVERING OR ENCLOSING WORK. DO NOT ALLOW OR CAUSE ANY OF THE WORK OF THIS SECTION TO BE COVERED UP OR ENCLOSED UNTIL IT HAS BEEN OBSERVED AND ACCEPTED BY THE CIRCLE K PROJECT ENGINEER AND BY ALL OTHER AUTHORITIES HAVING JURISDICTION.

V. THE ENTIRE SYSTEM SHALL BE WARRANTED FOR A PERIOD OF ONE (1) YEAR BEGINNING WITH OWNER'S ACCEPTANCE OF THE WORK. ALL LABOR AND MATERIALS NECESSARY TO REPAIR OR REPLACE THE SYSTEM, OR PORTIONS THEREOF, DURING THAT TIME SHALL BE WARRANTED FOR A PERIOD OF ONE (1) YEAR FROM THE REPAIR OR REPLACEMENT.

W. INSTRUCT OWNER'S REPRESENTATIVE IN THE OPERATION OF THE SYSTEMS.

X. PROVIDE ONE REPRODUCIBLE AS-BUILT DRAWING AND AN OPERATION AND MAINTENANCE MANUAL. AS A MINIMUM, THE MANUAL SHALL CONTAIN:

1. A COMPLETE LIST OF ALL EQUIPMENT AND APPURTENANCES WITH EQUIPMENT DESIGNATIONS (PER DRAWINGS), MANUFACTURERS, AND CATALOG NUMBERS.
2. COPIES OF MANUFACTURERS' BROCHURES AND INSTRUCTIONS FOR OPERATION AND MAINTENANCE OF ALL MECHANICAL EQUIPMENT, INCLUDING REPLACEMENT PARTS LISTS.
3. TYPED SYSTEM OPERATION AND MAINTENANCE INSTRUCTIONS, INCLUDING INSPECTION, LUBRICATION, AND SERVICE INSTRUCTIONS AND SCHEDULES.
4. LIST OF NAMES, ADDRESSES AND PHONE NUMBERS OF DISTRIBUTORS OF ALL EQUIPMENT AND APPURTENANCES.
5. MANUFACTURERS' WARRANTIES.

## CODE INFORMATION

A. 2009 IBC, IAMPO 2009 UMC, 2011 NEC, 2008 NEW MEXICO ELECTRICAL SAFETY CODE, AND IAMPO 2009 UPC.

ALL SYSTEMS SHALL BE IN COMPLIANCE WITH THE ABOVE CODES AS ADOPTED BY THE COUNTY OF SAN JUAN.

B. OUTDOOR AIR VENTILATION PROVIDED AND BASED ON CHAPTER 4 OF THE 2009 UMC.

1. SEE SHEET M3.0 FOR VENTILATION CALCULATIONS.

C. ALL ROOFTOP EQUIPMENT SHALL BE PERMANENTLY IDENTIFIED AS TO THE AREA SERVED WITH A RUST-PROOF METAL NAMEPLATE PER 2009 UMC.

D. DUCT SMOKE DETECTORS REQUIRED PER SECTION 609 2009 UMC SHALL BE INSTALLED IN THE RETURN DUCTWORK AS SHOWN ON THE PLANS. IF A FIRE ALARM SYSTEM IS AVAILABLE, THAT THE DUCT SMOKE DETECTOR(S) SHALL BE CONNECTED TO THE FIRE ALARM SYSTEM AND IF A FIRE ALARM SYSTEM IS NOT AVAILABLE, PROVIDE A VISIBLE AND AUDIBLE SUPERVISORY SIGNAL AT A CONSTANTLY SUPERVISED LOCATION TRIGGERED BY THE ACTIVATION OF A DUCT SMOKE DETECTOR. INCLUDE THE AIR DUCT DETECTOR TROUBLE INDICATOR (LED AT THE CEILING BELOW THE DUCT DETECTOR).

E. EQUIPMENT AND APPLIANCES SHALL BE INSTALLED AS REQUIRED BY THE TERMS OF THEIR APPROVAL, IN ACCORDANCE WITH THE CONDITIONS OF THE LISTING, THE MANUFACTURERS INSTALLATION INSTRUCTIONS AND THIS CODE. MANUFACTURERS INSTALLATION INSTRUCTIONS SHALL BE AVAILABLE ON THE JOB SITE AT THE TIME OF INSPECTION PER 2009 UMC SECTION 304.1.

F. ACCESS TO ROOF MOUNTED EQUIPMENT COMPLIES WITH 2009 UMC. SEE ARCHITECTURAL DRAWINGS FOR ROOF ACCESS DETAILS.

## MATERIALS SPECIFICATIONS

1. ALL DUCTWORK SHALL BE CONSTRUCTED FROM NEW HOT DIPPED GALVANIZED SHEET IRON OR STEEL, ASTM A-120, IN ACCORDANCE WITH THE UMC, ASHRAE GUIDE, AND SMACNA STANDARDS FOR GAGE AND REINFORCEMENT. ALL LOW VELOCITY AIR CONDITIONING SUPPLY AIR AND RETURN AIR DUCTWORK SHALL BE 2-INCH DUCT CONSTRUCTION. CONSTRUCT AND ERECT DUCTWORK IN ACCORDANCE WITH THE CURRENT ISSUES OF THE UMC, SMACNA STANDARDS AND ASHRAE HANDBOOKS. DUCTS SHALL CONFORM TO DIMENSIONS ON THE DRAWINGS UNLESS LOCATION OF STRUCTURAL MEMBERS PROHIBITS. IN CASE OF CHANGE IN DIMENSIONS, CROSS SECTIONAL AREAS SHALL BE MAINTAINED.
2. INSULATE THE FIRST 10 FEET OF ALL RECTANGULAR SUPPLY AIR AND ALL RECTANGULAR RETURN AIR SHEET METAL DUCTWORK INTERNALLY WITH JOHNS-MANVILLE LINACOUSTIC RC FIBERGLASS DUCT LINER WITH REINFORCED COATING SYSTEM, THICKNESS 1" (R=6.0) AND DENSITY 1-1/2 PCF. ALL OTHER RECTANGULAR SUPPLY AIR AND RIGID ROUND DUCTWORK SHALL BE INSULATED WITH 2" THICK (R=6.0) JOHNS-MANVILLE MICROLITE DUCT WRAP WITH FSK VAPOR BARRIER.
3. CONDENSATE DRAIN PIPING SHALL BE ASTM B-88, TYPE "M" HARD DRAWN COPPER WITH WROT COPPER FITTINGS AND SOLDERED JOINTS, 50/50 SOLDER. INSULATE WITH 1/2" THICK FLEXIBLE CLOSED CELL FOAMED PLASTIC PIPE INSULATION, ARMSTRONG ARAMFLEX, OR EQUAL FOR ENTIRE LENGTH. FITTINGS FIELD FABRICATED OF NESTING SIZES, SECURED WITH ADHESIVE. REFRIGERANT SUCTION LINES SHALL BE INSULATED TO 1" THICKNESS.
4. FLEXIBLE DUCTS SHALL BE THERMAFLEX II TYPE M-KE, FACTORY FABRICATED ASSEMBLY, SPIRAL CONSTRUCTION, FIBERGLASS BLANKET INSULATION (R=6.0), AND MYLAR SHEATH. FLEXIBLE DUCTS UL LISTED FOR CLASS 0 DUCT AND COMPLY WITH NFPA-90A.
5. PROVIDE APPROVED FIRE AND SMOKE RATED FLEXIBLE CONNECTIONS BETWEEN FANS AND DUCTS.
6. INSTALL ALL EQUIPMENT IN ACCORDANCE WITH MANUFACTURERS' INSTRUCTIONS AND RECOMMENDATIONS.
7. MAKE ALL DUCT ELBOWS RIGHT ANGLE TYPE WITH DOUBLE-THICKNESS TURNING VANES OR CONSTRUCT WITH A CENTERLINE RADIUS 1-1/2 TIMES THE DUCT WIDTH.
8. PROVIDE WEATHER-PROOF FLASHINGS AT ALL DUCT AND PIPE PENETRATIONS THROUGH THE BUILDING WALLS AND ROOF. AS A MINIMUM, FLASHINGS SHALL BE DESIGNED AND INSTALLED IN ACCORDANCE WITH SMACNA STANDARDS. FLASHINGS SHALL BE GUARANTEED WEATHERPROOF FOR THE DURATION OF THE GUARANTEE.
9. SUPPORT ALL HVAC UNITS, DUCTWORK, PIPING AND OTHER APPURTENANCES. DO NOT SCREW OR DRIVE FASTENERS INTO NON-STRUCTURAL COMPONENTS SUCH AS ROOF DECKS OR WALLS.
10. THOROUGHLY CLEAN ALL COMPONENTS AND REMOVE ALL DIRT, SCALE, OIL, AND OTHER FOREIGN SUBSTANCES. PROVIDE CLEAN AIR FILTERS FOR ALL EQUIPMENT.
11. FURNISH ACCESS DOORS AND PANELS AT WALLS, CEILINGS AND DUCTWORK FOR ACCESS TO HARDWARE, CONTROLS, OPERATOR, DRIVE MECHANISMS AND VOLUME DAMPERS.

## SYMBOLS LIST NOTES

1. SYMBOLS LISTS, NOTES, ABBREVIATIONS, ETC. ARE FOR GENERAL REFERENCE ONLY. THE PRESENCE OF SYMBOLS, NOTES, ABBREVIATIONS, ETC. DOES NOT IMPLY ITS USE ON THIS PROJECT. REFER TO DRAWINGS FOR SPECIFIC SYMBOLS, NOTES, ABBREVIATIONS, ETC. USED.

## DUCT SMOKE DETECTOR TESTING

TESTING AND INSPECTION OF SMOKE CONTROL DEVICES

A. PRIOR TO TESTING SMOKE CONTROL DEVICES:

1. VERIFY PROPER OPERATION OF EACH EXISTING SMOKE DETECTOR. ACTIVATION TESTING SHALL BE PERFORMED USING "CANNED SMOKE" ACCEPTABLE TO THE AUTHORITIES HAVING JURISDICTION.
2. VERIFY ACTIVATION OF THE EXISTING SMOKE DETECTOR SHUTS DOWN THE APPROPRIATE AIR-MOVING SYSTEM(S). VERIFY ACTIVATION OF THE SMOKE DETECTOR IS SHOWN BY THE FIRE ALARM SYSTEM WHERE MONITORING IS REQUIRED.

B. INSPECTION & TESTING OF SMOKE CONTROL DEVICES:

1. TESTING OF FIRE/SMOKE DAMPERS AND SMOKE DETECTORS SHALL BE ACCOMPANIED BY THE ELECTRICIAN AND/OR THE CONTROLS SYSTEM SUPPLIER. IF THE BUILDING HAS A FIRE ALARM SYSTEM, A REPRESENTATIVE OF THE MANUFACTURER MUST BE PRESENT DURING THE TESTING.

## INSTALLATION NOTES

ALL AC UNITS TO BE MOUNTED ON FACTORY TYPE CURB, LEVEL PLATFORM UNITS AND MOUNTING SYSTEM TO BE SECURED SUBSTANTIALLY TO SUSTAIN VERTICAL AND HORIZONTAL LOADS.

PROVIDE FRESH AIR INTAKE (O.S.A. INTAKE) OF 15% UNLESS OTHERWISE NOTED ON PLANS OR EQUIPMENT SCHEDULE. INTAKE TO HAVE BUG SCREEN AND BACKDRAFT DAMPER.

ALL FRESH AIR INTAKES TO BE MINIMUM OF 10'-0" AWAY OR 3'-0" BELOW ALL EXHAUST OR PLUMBING VENTS.

ALL EXHAUST FANS BEING RUN THRU ROOF PROVIDE COVERED FLASHING WITH SCREEN SEALED WATERTIGHT AT ROOF PENETRATION.

ALL EXHAUST FANS, SUPPLY FANS AND FRESH AIR INTAKES SHALL HAVE AUTOMATIC OR GRAVITY DAMPERS THAT ARE CLOSED ON FAN SHUT DOWN.

ALL CONDENSATE DRAINS ABOVE ROOF TO BE 1" CU WITH "P" - TRAP AND VENT, HAVE 2 % MINIMUM SLOPE, AND DRAIN TO APPROVED RECEPTACLE, DRAIN OR LAVATORY TAIL PIECE. ALL CONDENSATES TO BE RUN TO MEET THE 2009 IBC, IAMPO 2009 UMC, 2011 NEC, 2008 NEW MEXICO ELECTRICAL SAFETY CODE, AND IAMPO 2009 UPC.

VERIFY PLACEMENT OF EQUIPMENT ON JOB SITE. COORDINATE PLACEMENT WITH GENERAL CONTRACTOR.

ALL AC UNITS WILL BE PERMANENTLY IDENTIFIED AS TO THE AREA THEY SERVE.

ALL MECHANICAL EQUIPMENT, DUCTWORK AND REGISTERS SHALL BE ANCHORED TO RESIST SEISMIC FORCES. THE SEISMIC BRACING / ANCHORAGE OF DUCTWORK AND EQUIPMENT SHALL BE IN ACCORDANCE WITH, "GUIDELINES FOR SEISMIC RESTRAINTS OF MECHANICAL AND PLUMBING SYSTEMS", PUBLISHED BY S.M.A.C.N.A. AND P.P.I.C., APPROVED BY O.S.A., AND ALL LOCAL AND I.B.C. CODES AND STANDARDS.

## VENTILATION VERIFICATION

AN AIR BALANCE REPORT SHOWING FRESH AIR COMPLIANCE IS REQUIRED BY THE MECHANICAL INSPECTOR FOR FINAL INSPECTION APPROVAL. VENTILATION SYSTEMS SHALL BE BALANCED BY AN APPROVED METHOD. A BALANCE REPORT SHALL VERIFY THAT THE VENTILATION SYSTEM IS CAPABLE OF SUPPLYING AIRFLOW RATES REQUIRED BY CHAPTER 4 OF THE 2009 UMC.

## 2009 IECC WITH COMPLIANCE NOTES

A. DESIGN HEATING AND COOLING LOADS FOR THE BUILDING HAVE BEEN CALCULATED USING CARRIER HAP USING PROCEDURES RECOMMENDED BY ASHRAE.

B. ALL EQUIPMENT AND SYSTEMS HAVE BEEN SIZED TO BE NO GREATER THAN NEEDED TO MEET CALCULATED LOADS.

C. HUMIDIFICATION SYSTEMS HAVE NOT BEEN PROVIDED ON THIS PROJECT.

D. EACH HEATING OR COOLING SYSTEM ZONE HAS BEEN PROVIDED WITH ITS OWN TEMPERATURE CONTROL DEVICE.

E. THE PROGRAMMABLE THERMOSTATS SHALL BE CAPABLE OF SETTING BACK TEMPERATURE TO 55 DEGREES F DURING HEATING AND SETTING UP TO 85 DEGREES F DURING COOLING, CAPABLE OF AUTOMATICALLY SETTING BACK OR SHUTTING DOWN SYSTEMS DURING UNOCCUPIED HOURS USING 7-DIFFERENT DAY SCHEDULES, HAVE A ACCESSIBLE MANUAL 2-HOUR OVERRIDE THAT ALLOWS TEMPORARY OPERATION OF THE SYSTEM FOR UP TO 2 HOURS, HAVE A BATTERY BACK-UP CAPABLE OF MAINTAINING PROGRAMMED SETTINGS FOR AT LEAST 10 HOURS WITHOUT POWER. A SETBACK OR SHUTOFF CONTROL IS NOT REQUIRED ON THERMOSTATS THAT CONTROL SYSTEMS SERVING AREAS THAT OPERATE CONTINUOUSLY SUCH AS THE ELEVATOR EQUIPMENT ROOM AND ELECTRICAL ROOMS IF APPLICABLE.

F. OUTDOOR-AIR SUPPLY SYSTEMS WITH DESIGN AIRFLOW RATES GREATER THAN 3000 CFM AND ALL EXHAUST SYSTEMS MUST HAVE DAMPERS THAT ARE AUTOMATICALLY CLOSED WHILE EQUIPMENT IS NOT OPERATING IF APPLICABLE.

G. OUTSIDE VENTILATION HAS BEEN DESIGNED PER CHAPTER 4 OF THE 2009 UMC.

H. ALL SUPPLY AND RETURN AIR DUCTS MUST BE INSULATED WITH A MINIMUM OF R-6 (2" MINIMUM THICKNESS DUCT WRAP OR 1-1/2" WHEN DUCT IS LINED) PER SECTION 503.2.7 OF 2009 IECC.
ALL DUCTS LOCATED OUTSIDE THE BUILDING MUST BE INSULATED WITH A MINIMUM OF R-8.

I. ALL JOINTS, LONGITUDINAL AND TRANSVERSE SEAMS, AND CONNECTIONS IN DUCTWORK MUST BE SECURELY SEALED USING WELDMENTS, MECHANICAL FASTENERS WITH SEALS, GASKETS, OR MASTICS, MESH AND MASTIC SEALING SYSTEMS, OR TAPES. TAPES AND MASTICS MUST BE LISTED AND LABELED IN ACCORDANCE WITH UL 181A OR UL 181B.

J. MECHANICAL FASTENERS AND SEALS, MASTICS, OR GASKETS MUST BE USED WHEN CONNECTING DUCTS TO FANS AND OTHER AIR DISTRIBUTION EQUIPMENT, INCLUDING MULTIPLE-ZONE TERMINAL UNITS.

K. OPERATOR AND MAINTENANCE DOCUMENTATION MUST BE PROVIDED TO THE OWNER THAT INCLUDES EQUIPMENT INPUT AND OUTPUT CAPACITY AND REQUIRED MAINTENANCE ACTIONS, EQUIPMENT OPERATION AND MAINTENANCE MANUALS, HVAC SYSTEM CONTROL MAINTENANCE AND CALIBRATION INFORMATION, INCLUDING WIRING DIAGRAMS, SCHEMATICS, AND CONTROL SEQUENCE DESCRIPTIONS. DESIRED OR FIELD DETERMINED SET POINTS MUST BE PERMANENTLY RECORDED ON THE CONTROL DRAWINGS, AT CONTROL DEVICES, OR, FOR DIGITAL CONTROL SYSTEMS, IN PROGRAMMING COMMENTS. A COMPLETE NARRATIVE OF HOW EACH SYSTEM IS INTENDED TO OPERATE.

L. EACH SUPPLY AIR OUTLET OR DIFFUSER MUST HAVE ITS OWN BALANCING DEVICE. ACCEPTABLE BALANCING DEVICES INCLUDE ADJUSTABLE DAMPERS LOCATED WITHIN THE DUCTWORK AND SUPPLY AIR DIFFUSERS.

M. WATER-HEATING EQUIPMENT AND HOT WATER STORAGE TANKS SHALL MEET THE REQUIREMENTS OF TABLE 504.2 OF 2009 IECC.
THE EFFICIENCY SHALL BE VERIFIED THROUGH DATA FURNISHED BY THE MANUFACTURER OR THROUGH CERTIFICATION UNDER AN APPROVED CERTIFICATION PROGRAM.

N. FOR AUTOMATIC-CIRCULATING HOT WATER SYSTEMS, PIPING SHALL BE INSULATED WITH 1" OF INSULATION HAVING A CONDUCTIVITY NOT EXCEEDING 0.27 BTU-IN/(H xFT2x°F). THE FIRST 8'-0" OF PIPING IN NON-CIRCULATING WATER HEATING SYSTEMS SERVED BY EQUIPMENT WITHOUT INTEGRAL HEAT TRAPS SHALL BE INSULATED WITH 1/2" PIPE INSULATION OF MATERIAL HAVING CONDUCTIVITY NOT EXCEEDING 0.27 BTU-IN/(H xFT2x°F).

## ABBREVIATIONS

| ABBREVIATION | DESCRIPTION |
|---|---|
| AC | AIR CONDITIONING UNIT |
| AD | ACCESS DOOR |
| AFF | ABOVE FINISHED FLOOR |
| AL | ACOUSTICAL LINING |
| AMP | AMPERE (AMPS) |
| AP | ACCESS PANEL |
| BF | BELOW FLOOR |
| BHP | BRAKE HORSE POWER |
| BOD | BOTTOM OF DUCT |
| BOP | BOTTOM OF PIPE |
| BTU | BRITISH THERMAL UNIT |
| BTUH | BTU PER HOUR |
| BD | BACKDRAFT DAMPER |
| C | CELSIUS |
| CI | CAST IRON |
| CFM | CUBIC FEET PER MINUTE |
| CO | CLEANOUT |
| CONT. | CONTINUATION |
| D | DRAIN |
| Db | DECIBEL |
| DB | DRY BULB |
| DBT | DRY BULB TEMPERATURE |
| DIA. | DIAMETER |
| DX | DIRECT EXPANSION |
| EFF | EFFICIENCY |
| ENT | ENTERING |
| EXH | EXHAUST |
| EMCS | ENERGY MANAGEMENT CONTROL SYSTEM |
| °F | DEGREES FAHRENHEIT |
| FB | FLAT BOTTOM |
| FCO | FLOOR CLEANOUT |
| FCU | FAN COIL UNIT |
| FD | FLOOR DRAIN |
| FD | FIRE DAMPER |
| F.G. | FILTER GAUGE |
| FLEX | FLEXIBLE |
| FPM | FEET PER MINUTE |
| FPS | FEET PER SECOND |
| FS | FLOOR SINK |
| FT | FLAT TOP |
| FT. | FEET |
| FSD | FIRE/SMOKE DAMPER |
| GA | GAUGE |
| GAL | GALLONS |
| GPM | GALLONS PER MINUTE |
| GPH | GALLONS PER HOUR |
| HB | HOSE BIBB |
| HD | HAND DAMPER (VOLUME DAMPER) |
| HORZ | HORIZONTAL |
| HP | HORSEPOWER |
| HR | HOUR(S) |
| IN | INCHES |
| KVA | KILOVOLT-AMPERE |
| KW | KILOWATT |
| KWH | KILOWATT HOUR |
| LBS | POUNDS |
| MAX | MAXIMUM |
| MA | MAIN AIR (CONTROLS) |
| MCC | MOTOR CONTROL CENTER |
| MIN | MINIMUM |
| N/A | NOT APPLICABLE |
| NC. | NOISE CRITERIA |
| NIC | NOT IN CONTRACT |
| #,NO. | NUMBER (QUANTITY) |
| NO | NORMALLY OPEN |
| NC | NORMALLY CLOSED |
| NTS | NOT TO SCALE |
| OA | OUTSIDE AIR |
| OBD | OPPOSED BLADE DAMPER |
| PRV | PRESSURE REDUCING VALVE |
| PSI | POUNDS PER SQUARE INCH |
| PSIG | POUNDS PER SQUARE INCH GAUGE |
| PD | PRESSURE DROP |
| QTY | QUANTITY |
| QUAD | QUADRANT |
| RA | RETURN AIR |
| REQ | REQUIRED |
| RH | RELATIVE HUMIDITY |
| RM | ROOM |
| RPM | REVOLUTIONS PER MINUTE |
| SA | SUPPLY AIR |
| SCD | SMOKE CONTROL DAMPER |
| S.DPR. | SMOKE DAMPER |
| SP | STATIC PRESSURE (INCHES OF WATER) |
| SPEC | SPECIFICATION |
| SQ | SQUARE |
| SDVV | SINGLE DUCT VARIABLE VOLUME |
| ST | SOUND TRAP |
| TEMP | TEMPERATURE |
| TSTAT | THERMOSTAT |
| TP | TOTAL PRESSURE (INCHES OF WATER) |
| TYP | TYPICAL |
| UC | UNDERCUT |
| V | VOLTS |
| VAC | VOLTS, ALTERNATING CURRENT |
| VAV | VARIABLE AIR VOLUME |
| VEL | VELOCITY |
| VERT | VERTICAL |
| VTR | VENT THRU ROOF |
| WB | WET BULB |
| WCO | WALL CLEANOUT |
| WH | WALL HYDRANT |
| Z | ZONE |

## ANNOTATION SYMBOLS

| SYMBOL | DESCRIPTION |
|---|---|
| (X) | KEYED NOTE |
| XXX | ROOM NUMBER |
| * / * / * | SYMBOL INDICATES NEW EQUIPMENT<br>NUMBER REFERS TO SPECIFIC EQUIPMENT<br>OUTSIDE AIR CFM REQUIRED |
| XX / XX | HEX SYMBOL INDICATES NEW EQUIPMENT<br>NUMBER REFERS TO SPECIFIC EQUIPMENT<br>IDENTIFIED IN EQUIPMENT SCHEDULE |
| X | REVISION TRIANGLE<br>REVISION NUMBER |
| XXX / XXX | DETAIL NUMBER<br>DETAIL SYMBOL<br>DRAWING WHERE DETAIL APPEARS |
| X | SECTION LETTER<br>SECTION CUT SYMBOL |
| X / XXX | SECTION LETTER<br>SECTION CUT SYMBOL<br>DRAWING WHERE SECTION APPEARS |
| | NORTH ARROW |

## DUCTWORK SYMBOLS

| SYMBOL | DESCRIPTION |
|---|---|
| 12x8 | RECTANGULAR DUCT, WIDTH x DEPTH (INCHES) |
| 12ø | ROUND DUCT (INCHES) |
| | FLEXIBLE DUCT |
| | CONCENTRIC DUCT REDUCER |
| | SUPPLY DUCT - SECTION/ END VIEW |
| | RETURN DUCT - SECTION/ END VIEW |
| | EXHAUST DUCT - SECTION/ END VIEW |
| | CROSS SECTION THROUGH ROUND DUCT EXHAUST AIR DUCT |
| | RADIUS ELBOW 90° |
| | RETURN AIR CEILING GRILLE |
| | CEILING DIFFUSERS |
| | EXHAUST CEILING REGISTER OR GRILLE |
| T | ROOM THERMOSTAT |
| S | ROOM TEMPERATURE SENSOR |
| | DUCT SMOKE DETECTOR (DSD) |
| | MANUAL VOLUME DAMPER (VD) |
| | CEILING MOUNTED EXHAUST FAN |
| | ROOF MOUNTED EXHAUST FAN |
| | CONTINUATION OF DUCT OR PIPE |

## DIFFUSER,REGISTER + GRILLE SYMBOLS

| SYMBOL | DESCRIPTION |
|---|---|
| X / XX / XXX | SYMBOL (AS SHOWN ON SCHEDULE)<br>NECK SIZE (DIA.)<br>CFM |

**GreenbergFarrow**
19000 MacArthur Blvd., Suite 250
Irvine, CA 92612
t: 949 296 0450 f: 949 296 0437

**COPYRIGHT NOTICE**
This drawing is the property of the above referenced Professional and is not to be used for any purpose other than the specific project and site named herein, and cannot be reproduced in any manner without the express written permission from the Professional

**ISSUE/REVISION RECORD**

| DATE | DESCRIPTION |
|---|---|
| 03/28/14 | PLAN CHECK SUBMITTAL |

**PROFESSIONAL SEAL**

JAMES NICHOLAS LEDYARD
NEW MEXICO
20862
LICENSED PROFESSIONAL ENGINEER
MAR 28 2014

**PROFESSIONAL IN CHARGE**
JAMES LEDYARD

**PROJECT MANAGER**
DARCY HASBERRY

**QUALITY CONTROL**
JAMES LEDYARD

**DRAWN BY**
DARCY HASBERRY

**PROJECT NAME**

# CIRCLE K STORES, INC.

**SAN JUAN COUNTY**
**NEW MEXICO**

**819 NM 516**
**FLORA VISTA**
**SAN JUAN COUNTY, NM**

CIRCLE K STORES INC.

**PROJECT NUMBER**
20130787.0

**SHEET TITLE**
NOTES AND LEGEND - MECHANICAL

**SHEET NUMBER**
M1.0

Drawing Name: P:\2013\20130787\0\540 AT ME Construction Documents\Flora Vista NM - Circle K\Produced\20130787\0-M1.0.dwg Last Modified: Mar 28, 2014 - 2:07pm Plotted on: Mar 28, 2014 - 2:08pm by dhasber